

VOC Content Test Certificate

Thursday 18th August 2022

Supplier: AMBITEC (NZ) Limited (34 Frost Road, Mount Roskill, Auckland, 1041, New Zealand).

Sample Description: Ambitec Suave W-base

Date Tested: August 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


| | |
|--|--|
| Specification New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B | Ambitec Suave W-base |
| Primers, Sealers, and Prep Coats limit: 65 grams per Litre | 2 grams per Litre as VOC content per material |
| <p><i>We hereby certify that Ambitec Suave W-base product is below the VOC Content limits of chosen categories specified by Green Star Design, New Zealand Green Building Council.</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
Bsc (Biotechnology)
Senior Consultant

P22080019

VOC Content Test Certificate

Thursday 18th August 2022

Supplier: AMBITEC (NZ) Limited (34 Frost Road, Mount Roskill, Auckland, 1041, New Zealand).

Sample Description: Ambitec Suave D-base

Date Tested: August 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


| | |
|--|--|
| Specification New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B | Ambitec Suave D-base |
| Primers, Sealers, and Prep Coats limit: 65 grams per Litre | <1 grams per Litre as VOC content per material |
| <p><i>We hereby certify that Ambitec Suave D-base product is below the VOC Content limits of chosen categories specified by Green Star Design, New Zealand Green Building Council.</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
Bsc (Biotechnology)
Senior Consultant

P22080019

VOC Content Test Certificate

Thursday 18th August 2022

Supplier: AMBITEC (NZ) Limited (34 Frost Road, Mount Roskill, Auckland, 1041, New Zealand).

Sample Description: Ambitec Universal Primer/Sealer

Date Tested: August 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


| | |
|---|--|
| Specification New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B | Ambitec Universal Primer/Sealer |
| Primers, Sealers, and Prep Coats limit: 65 grams per Litre | 3 grams per Litre as VOC content per material |
| <p><i>We hereby certify that Ambitec Universal Primer/Sealer product is below the VOC Content limits of chosen categories specified by Green Star Design, New Zealand Green Building Council.</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
Bsc (Biotechnology)
Senior Consultant

P22080019